

Campus	Driving up to building. Look for fallen trees and/or physical damage to the building/roof. Downed trees? Power lines? If yes, please describe below.	Entering the building: Is the power on to the entire building? Are the exit signs on?	Entering the building: Is the fire panel working or does it need to be reset (making a noise)?	Entering the building: Please pick-up the phone and see if there is a dial tone. Please call yourself to ensure. Is the phone system working?	Entering the building: Check water throughout the front office suite. Please flush all the toilets, run the water at each sink.	Throughout the building: Please walk every classroom and hallway. Do you see any signs of water leaking?	Cafeteria: Is there water for cooking?	Cafeteria: Is there power for cooking?	Is the cafeteria safe?	Is the building safe and can we allow the second phase to walk the building?	Maintenance/Facility notes before physical inspection
Alice Douse ES	None	Yes	Working	Working	All Good	Upstairs sink had flooded four 2nd floor classrooms and two 1st floor classrooms. Water in room 124 and in bathroom near room # 124. Water on floor in rooms # 232, 230, 229 and 226. (Plumbers)	Yes	Yes	Yes	Yes	Done: 2:15 - Plumber sink flooded 4 second floor classrooms and 2 first floor classrooms Flooded stopped 2:20 - Renovation is needed, scheduling with contractor
Audie Murphy MS	None	Yes	Couldn't assess due to standing water in the foyer. Accessed the building through a side entrance	Couldn't assess due to standing water in the main hallway.	Couldn't assess due to standing water in the main hallway.	Water leakage and damage in many classrooms, the athletic wing, cafeteria, gym, library, front office and entrance vestibule.	Yes	Yes	No. Standing water on the floor in the cafeteria	I do not think so.	Audie Murphy MS - leak in the Athletic wing (from boiler space) 2:16 @ 5:15pm - FD shut off water main Scheduled for remediation contractor to come out and remove water (contractor scheduled for 2:19) 2:19 @ 10:25am: Remediation contractor discovered pipe behind building that is busted (inside boiler room). Maintenance is on their way 2:19 - Plumbing contractor on site, making repairs. 2:19 - Plumbing repair completed, the replacement part is still needed for the boiler but building should be functional Remediation contractor has found that many classrooms and offices have some water damage. Crews will be on site tomorrow to begin work. 2:20 - Boiler still down, so hot water Standing water on floor in Cafeteria, vestibule, and front office area Kitchen bridge and fence off
Bidartre ES	None	Yes Note: Front key pad not working.	Working	Working	All Good	Boys restroom in 100 hallway 1 floor will not turn off.	Yes	Yes	Yes	Yes	
Bookhaven ES	None	Yes Note: Flashing light in room 105. Check light switch in room 110.	Working	Working	All Good	Leak in multiple classrooms, hallways & restrooms. Water puddles in room 196 but no signs of leaking.	Yes	Yes	Yes	No, until remediation is complete and other issues in question.	Classrooms/hallways 2:16 @ 9am - water leaks observed on security hallway 2:16 - Maintenance shut off water at school locations Remediation contractor has removed standing water from floors and installed fan Shut rock may need to be removed at wall base in some areas Plumbing contractor scheduled to make repairs on 2:19 2:19 @ 6pm - Contractor repaired water lines in walls, wall tile and ceiling out to make repairs Contractor water line at base-bis, will return for repair. May be additional water in the building, remediation contractor may need to return 2:19 @ 6pm - Maintenance an additional leak in room 104 Maintenance shut off water to the room Plumber sent to campus to fix the leak tonight Remediation contractor may need to revisit campus 2:20 @ 6pm - Water has been extracted from all areas except roof leak
Buckley Stadium						Busted water main pipe between two locker restrooms, 3' of standing water in elevator room, vestibule and stairwell.					
Cacer Center	None	Yes	Working	Working	No Water	Leak in fire riser behind kitchen. There is pooled water in several places by room # 209. There is water in bathroom pooling around water in room 109.	Yes	Yes	Yes	Yes	Cacer Center 2:16 @ 6:45pm - Greenhouse busted pipes, staff shut off 2:19 @ 6pm - Dr. Porterfield notified KSD that there is no water without water 2:19 @ 3:30pm - Fire riser leaking at main building behind kitchen. KSD Maintenance shutting off 2:20 - Main fire riser leaking. Plumbers to repair.
Caravos ES	None	Yes	Working	Working	Girls RR Hallway 1 one faucet won't turn off Boys RR Hallway 2 large water pressure when flushing and it spills out of initial (green) and one sink doesn't work Boys and Girls RR by cafeteria lots of water pressure when flushing and girls have one sink that doesn't work Left water fountain doesn't work Dripping stopped toilet off cafeteria with faucet in it. Girls RR at Stairwell C - 2 sinks don't work and 1 is running and won't turn off Upstairs by DAREP girls restroom second sink on and won't turn off as last sink won't come on.	All Good	Yes	Yes	Sprinkler system leak in cafeteria vestibule	Yes	Caravos ES - 2:18 - Busted water line City is going to shut off the main Sprinkler head in Cafeteria vestibule was busted Plumbing contractor shut off fire sprinkler main line. Building still has water but no sprinklers. Remediation contractor or custodians will remove water. 2:19 @ 10:25am - Onco notified us that the school shows to have power. Custos are still down. 2:19 @ 6pm - Fire alarm contractor completed repairs to sprinkler system. Fire alarm contractor reported need still 1 minor issue related to sprinklers, should be addressed tomorrow as sprinklers can be turned back on. Fire alarm contractor to return to campus tomorrow morning. Remediation contractor has extracted all water and installed fan for drying. 2:20 @ 9:30am - Sprinkler system repair complete, fire alarm repair complete. Water extraction completed vestibule, all areas are dry.
Cedar Valley ES	None	Yes	Working	Working	All Good	Yes. Two toilets (center) in the boys restroom in the 100 hallway will not flush. One is dripping water when you try. Evidence of standing water in the boys restroom across from room 311. Can't enter electrical closets Evidence of water damage in the clinic (in 202) but cannot tell if it is new or old ceiling tiles are dry. Water damage in room 201. Water damage and standing water in rooms 102 and 103.	Yes	Yes	Not sure Beeping coming from kitchen. Can't tell what it's from.	Yes, with the exception of the 100 hallway.	Cedar Valley ES 2:19 @ 6pm - Room 101 - clogged sink running, room flooded Room 201 - puddle on floor with wet ceiling tiles, need to investigate 2:20 report in room 102 soaked, water fountain not working Room 201 puddle on floor with wet ceiling tiles Need cleaning/renovation Low water pressure in both activity building RR's
Charles Patterson MS	None	Power is on. Exit signs are on. No power issues noted except in front office.	The fire panel says there is a problem and lights would not come on.	Working	No Water	All Good	Yes	Yes	Yes	Yes. Water is off so unknown if there are any issues there.	Charles Patterson MS 2:20 - No water, Maintenance investigating
Clarke ES	None	Yes	Working	Working	All Good	Partial flood in classroom wing. Standing water in computer lab 301 and water to activities building.	Yes	Yes	Yes	Yes	Clarke ES - Busted water line in electrical room 2:15 @ 7:20pm - Fire alarm goes off, FD responded FD shut off water at select locations 2:15 - Working on scheduling plumber to make repairs 2:18 @ 4pm - Received notice from Ft. Hood emergency services that there is water coming out of the building 2:18 - KSD Maintenance found a sink overflowing inside the building and shut it off Partial flood in classroom wing Remediation contractor or custodians will remove water 2:19 - Plumbing contractor on site working Plumbing repairs are completed Remediation needed
Clear Creek ES	None	Yes	Beeping, supervisory caution	Working	All Good	All Good	Yes	Yes	Yes	Yes	
Clifton Park ES	None	Yes	Working	Working	All Good	Roof leak in library.	Yes	Yes	Yes, now that busted water pipe at sink in kitchen has been repaired.	Yes	Clifton Park ES 2:19 - Roof leak in Library 2:20 @ 9am - Busted pipe at sink in kitchen KSD plumber repaired line No need for remediation
Distribution Center						Busted pipe on floor of office area					Distribution Center 2:20 @ 9am - Busted pipe discovered, water in front office Remediation needed Plumber on site making repairs now Main line is busted, will demolition required Open - West side offices have water damage, School Nutrition 2:20 @ 6:30pm - Renovation contractor scheduled to be on site tomorrow
Early College HS	None	Yes	Working	Working	All Good	Concessions building had 4 busted lines. Room 107 smells like gas. Renter outside the library taking in the middle.	Yes	Yes	Yes	Yes	Early College HS 2:19 - Concessions building had 4 busted lines, maintenance shut off water 2:20 - Room 105 gas smell; Maintenance to investigate

Eastern Hills MS	None	Yes	Working	Working	Principals office roof leak, minor dripping on the floor- counselor office checked - work room checked	Water from roof is leaking on the floor of the hallway across from library also ceiling tile in front of library - LOTS of ponding in certain areas.	Yes	Yes	Yes	Water cleanup necessary	
Elision HS	None	Yes	Working	Working	All Good	The inside of the field house is flooded.	Yes	Yes	Yes	Main building boiler has a busted manifold. Elision HS 2:19 @ 2:30pm - KKD discovered that main building boiler has a busted manifold. No heat in building until we can receive parts and make repairs; working on a manifold. 2:20 @ 10:45am - Water coming up from ground outside of fieldhouse back of fieldhouse is flooded. Renovation contractor on site today working	
Facilities/Transportation	None	No, rooms 105, 107 & 134 lights are out	Working	Working	No toilets flushed	Multiple interior leaks.	Yes	Yes	Yes	Yes	
Fowler ES	None	Yes	Working	Working	No Water	Classroom 11 is already noted has a leak in the ceiling - trash collecting water and ceiling tile laying on floor. Several fresh water spots on ceiling tiles (fell wet to the touch) in the staff lounge. A couple of small wet spots on ceiling tiles in storage room within High School Administration office.	No	Yes	Yes	Yes	
Gateway MS and HS	None	Yes	Working	Working	No Water	Previous damage still evident; floor tiles soaked in back office corner. Leak in front office near clinic, lounge, standing water visible. Busted water pipe in restroom.	All Good	Yes	Yes	Yes	
Harker Heights ES	None	Yes	Note: booster trip 2 message on the box	Working	Working	All Good	Yes	Yes	Yes	Yes	
Harker Heights HS	None	Yes	Working	Working	Working	Water pipe inside wall at room 1303; standing water in room 1414; sewer concession building has busted pipe.	Yes	Yes	Yes	Yes	
Hay Branch ES	None	Yes	Humming sound in cafeteria	Working	Working	Low water pressure in kitchen sinks, won't flush. Low water pressure in boys bathroom on back hallway.	All Good	Yes	Yes	Yes	
Hynes ES	None	No, room 126 and 127 have no lights. Room 211 has no lights.	Working	Working	Working	All Good.	All Good.	Yes	Yes	Yes	
Mama ES	None	Power is on in some areas, but not in other areas. Reported to Facilities, several rooms had no lights working or had flickering lights. Here are the rooms with light issues: cafeteria, kitchen, 510, 512, 513, 101, 102, 103, 104, 203, 207, 208, 209, 401, 403, 406, 408, 409, 506, 508, 509, 509, 510, 511, 512, 513, 514, 515, 516, 517, 518, 519, 520, 521, 522, 523, 524, 525, 526, 527, 528, 529, 530, 531, 532, 533, 534, 535, 536, 537, 538, 539, 540, 541, 542, 543, 544, 545, 546, 547, 548, 549, 550, 551, 552, 553, 554, 555, 556, 557, 558, 559, 560, 561, 562, 563, 564, 565, 566, 567, 568, 569, 570, 571, 572, 573, 574, 575, 576, 577, 578, 579, 580, 581, 582, 583, 584, 585, 586, 587, 588, 589, 590, 591, 592, 593, 594, 595, 596, 597, 598, 599, 600, 601, 602, 603, 604, 605, 606, 607, 608, 609, 610, 611, 612, 613, 614, 615, 616, 617, 618, 619, 620, 621, 622, 623, 624, 625, 626, 627, 628, 629, 630, 631, 632, 633, 634, 635, 636, 637, 638, 639, 640, 641, 642, 643, 644, 645, 646, 647, 648, 649, 650, 651, 652, 653, 654, 655, 656, 657, 658, 659, 660, 661, 662, 663, 664, 665, 666, 667, 668, 669, 670, 671, 672, 673, 674, 675, 676, 677, 678, 679, 680, 681, 682, 683, 684, 685, 686, 687, 688, 689, 690, 691, 692, 693, 694, 695, 696, 697, 698, 699, 700, 701, 702, 703, 704, 705, 706, 707, 708, 709, 710, 711, 712, 713, 714, 715, 716, 717, 718, 719, 720, 721, 722, 723, 724, 725, 726, 727, 728, 729, 730, 731, 732, 733, 734, 735, 736, 737, 738, 739, 740, 741, 742, 743, 744, 745, 746, 747, 748, 749, 750, 751, 752, 753, 754, 755, 756, 757, 758, 759, 760, 761, 762, 763, 764, 765, 766, 767, 768, 769, 770, 771, 772, 773, 774, 775, 776, 777, 778, 779, 780, 781, 782, 783, 784, 785, 786, 787, 788, 789, 790, 791, 792, 793, 794, 795, 796, 797, 798, 799, 800, 801, 802, 803, 804, 805, 806, 807, 808, 809, 810, 811, 812, 813, 814, 815, 816, 817, 818, 819, 820, 821, 822, 823, 824, 825, 826, 827, 828, 829, 830, 831, 832, 833, 834, 835, 836, 837, 838, 839, 840, 841, 842, 843, 844, 845, 846, 847, 848, 849, 850, 851, 852, 853, 854, 855, 856, 857, 858, 859, 860, 861, 862, 863, 864, 865, 866, 867, 868, 869, 870, 871, 872, 873, 874, 875, 876, 877, 878, 879, 880, 881, 882, 883, 884, 885, 886, 887, 888, 889, 890, 891, 892, 893, 894, 895, 896, 897, 898, 899, 900, 901, 902, 903, 904, 905, 906, 907, 908, 909, 910, 911, 912, 913, 914, 915, 916, 917, 918, 919, 920, 921, 922, 923, 924, 925, 926, 927, 928, 929, 930, 931, 932, 933, 934, 935, 936, 937, 938, 939, 940, 941, 942, 943, 944, 945, 946, 947, 948, 949, 950, 951, 952, 953, 954, 955, 956, 957, 958, 959, 960, 961, 962, 963, 964, 965, 966, 967, 968, 969, 970, 971, 972, 973, 974, 975, 976, 977, 978, 979, 980, 981, 982, 983, 984, 985, 986, 987, 988, 989, 990, 991, 992, 993, 994, 995, 996, 997, 998, 999, 1000.	The fire/safety panel was turned off completely. Reported to Facilities.	Phones in the front office are not working.	Some areas in the building had water with low pressure and some areas with no running water at all. No water running in front office work rooms or in 500 hall restrooms.	All Good	Yes, but low pressure	Power is out in several areas in the kitchen.	Not at this time.	Not at this time.	
Ira Cross ES	Water leaks at irrigation backflow preventer.	Yes	Not making a loud alarm noise, but there was an intermittent clicking and a S sign moving across the screen, but it read "All Systems Normal."	Working	Working	Water working throughout office. Water drops on floor in men's restroom in office - no leaks apparent. Also low water pressure in men's restroom in office.	Kitchen and 201-215 Boys Restroom	Yes. Water dripping from steamer. Water would not turn off in hand washing sink. Hot water not flowing from left sink in main kitchen area - looks like hose not attached to water sprayed under sink. Also cart full of water by main kitchen area sinks. No apparent leak from ceiling.	Yes	Small water leaks in kitchen appliances, kitchen sink on due to motion sensor issue.	Yes
JPLC	None	Yes	Working	Working	Working, but low water pressure	All Good	Yes	Yes	Yes	Yes	
Killion HS	None	Yes	Working	Working	All Good	All Good	Unknown	Unknown	Unknown	Yes	
KLSS	None	Yes	Working	Working	All Good	All Good	N/A	N/A	Yes	Yes	
KLSS	None	Yes	Working	Working	Working	Limited, very low pressure. Some toilets did not flush. Some faucets did not turn on. Yellow water when turned on. This includes Student services and the Sped Villa that have water H & K/E/CAT. The entire compound has limited water pressure and limited if any ability to flush.	All Good	N/A	N/A	Yes	The building is safe, however, water and water pressure is minimal.
Liberty Hill MS	None	Yes, not sure if it was on in the front office.	Working	Working	Major damage to the front office and the principal's office.	Yes, major damage in the front office, the gym, and the boys equipment room.	No	Yes	Yes	Safe for admin.	
Live Oak Ridge MS	None	Yes	Fire Panel-Beeping battery issue on panel	Working	Working	All Good	Room 310 science room quarter inch standing water in front of 2 sinks.	Yes	Yes	Yes	
Mauer MS	None	Yes	Working	Working	Working	All Good	Standing water is in the kitchen, cafeteria, hallways leading to the gymnasium, girls locker room. No visible source to where the water is coming from.	Yes	Yes	Not at this time with standing water. I feel it is safe as there were dry patches on the floor where the water was standing. No visible ceiling damage or electrical wires exposed.	
Maud Moore Wood ES	None	Yes	Makes Noise	Working	Working	All Good	Water damage to the interior and exterior ceiling of the building foyer.	Yes	Yes	Yes	
Maxdale ES	None	Yes	Working	Working	Working	All Good	Floor/carpets of vestibule and part of library is wet and significant damage to the ceiling is seen in the vestibule.	Yes	Yes	Yes	

Meadows ES	None	Yes	Working	Working	All Good	All good except for minor drip on operator head outside entrance to cafeteria. Already a bucket there.	Yes	Yes	Yes	Yes	Meadows ES 2:19 - See slip from cafeteria ceiling. Maintenance to investigate.
Montague Village ES	None	Yes	Working	Working	All Good	Appears to be a fair amount of standing water coming from the "gym area" which flows over into the adjacent	Yes	Yes	Yes with caution due to nominal amount of water.	Yes	Montague Village ES 2:28 - standing water found in Activity Room and Cafeteria. Maintenance to investigate.
Mountain View ES	None	Yes	Working	Working	All Good	All Good	Yes	Yes	Yes	Yes	
Nolan MS	None	Yes	Working	Working	All Good	All Good	Yes	Yes	Yes	Yes	
Nolanville ES	None	Yes	Working	Working	All Good	All Good	Yes	Yes	Yes	Yes	Nolanville ES 2:19 - 3 classrooms found with no functioning HVAC. Maintenance to investigate. 2:20 - Elevator not working. Low water pressure in activity building Girls RR. Nolanville ES 2:19 - 3 classrooms found with no functioning HVAC. Maintenance to investigate. 2:20 - Elevator not working. Low water pressure in activity building Girls RR. Nolanville ES 2:19 - 3 classrooms found with no functioning HVAC. Maintenance to investigate. 2:20 - Elevator not working. Low water pressure in activity building Girls RR.
Obata Culp Hobby ES	None	Yes	Working	Working	All Good	All Good	Yes	Yes	Yes	Yes	
Palo Alto MS	None. Dishes are flowing freely which has the front yard holding a lot of water.	Yes	Working	Working	Halfway 200 and 300 - boys and girls restrooms, sink water is not working, toilets are not flushing	Broken water line in concession building	Yes	Yes	Yes	Note: heat was blowing steadily	2:21 (2:19 @ 9:30pm - Notified by KESD PD of fire alarm. Officer walking school. Room 214 is flooded, can hear water flowing in the wall. Contractor was onsite today repairing Broken water line in concessions building. water shut off
Pathways HS	Outside looks good. KESD facilities team members were here upon arrival. They advised that due to a hose bib break (room 207) as well as other water issues at the street, the water was turned off.	There is electrical power. Exit signs are on and working properly. The smell of natural gas is coming from the kitchen. Facilities was advised.	Working	Working	No Water	Water pooling under stove in kitchen. Doesn't seem to be running at this time. There is water damage (tile above) upstairs by room 1401 in hallway.	Not potable but there is water that runs in the kitchen. It may be on a separate system as the plumber was here when I arrived and said that the water had been shut off at the street. Water works in cafeteria, water fountains.	Yes. Power is on in kitchen. Small amount of natural gas emitting however. Facilities was notified.	Not at this time. There is the smell of natural gas emitting from the stove area.	Not at this time. Until the plumber says it's safe to enter after checking natural gas smell.	2:17 - City notified us of visible water leaks from outside of building and shut off water meter. 2:19 - Plumbing contractor is scheduled to arrive. 2:19 - Heat bib was busted pouring water outside of building; bib was replaced.
Peabody ES	None	Yes	Working	Working	All toilets and sinks inside were functioning. Portable 112 which an exterior building used as a restroom has frozen lines and ice in the toilets on the men's and women's sides.	Rooftop hose bib busted. One portable restroom frozen, no water.	Yes	Yes	Yes	Not until remediation is done and exterior portable with bathroom is fixed.	Peabody ES 2:17 - KESD notified city of possible water leak and reported that they shut off the meter. 2:19 - Roofing hose bib busted, contractor getting parts for repairs. There appears to be water line beneath freezer that is leaking water. KESD coordinating with contractor. 2:19 @ 9pm - Line above the freezer was busted, water leaked behind freezer and exited building. Contractor repaired line and system appears to be functioning properly. Need to inspect to determine if remediation is needed. 2:20 @ 12:30 - Report of slight gas smell in kitchen. Portable restroom frozen, no water.
Pershing Park ES	None	Yes	Working	Working	**Clinic faxer will not stop running)	Central hall Girls bathroom (by workroom 106) fire right faxer continues to run (I manually turned water off under sink to prevent continuous running. East Side of building upstairs boys restroom, there is Small amount of standing water under urinal in boys restroom. West side boys restroom large puddle under urinal (close to Em - 224)	Yes	Yes	Yes	Yes	
Property Management						Appears to be a roof leak in main office area					
Rancier MS	None	Yes	Working	Working	All Good	There is water by the girls locker room (west exit door) that appears to have come from outside. Water on floor on room 119. Standing water in concession stand restroom.	Yes	Yes	Yes	I would say you need to wait until remediation is complete.	Rancier MS 2:19 @ 7:30am - KESD notified of fire alarm. 8:30am - FD shut off water main to school. 9pm - Plumbing contractor is at campus investigating. 9pm - Plumbing repairs completed - 1 leak was overflowing upstairs. Need to investigate to determine if remediation is needed. Standing water in concession stand restroom, no visible leaks - Maintenance to investigate. 2:20 - Coordinating remediation
Recess Creek ES	None	Yes	Working	Working	No Water	Small amount of standing water in boys restroom in 400 hallway gathered near drain.	No water pressure	Yes there is power Note: over alarm sounding and standing water present	Puddle of water under and behind ovens. Alarm sounding from one of the ovens.	Not at this time. note: standing water and ovens alarm in cafeteria. Facilities working on water main.	Recess Creek ES 2:18 - No water on campus Maintenance following up with City.
Risk Management and Benefits	None	Yes	Working	Working	All Good	All Good	N/A	N/A	N/A	Yes	
Sageport ES	None	Yes	Fire alarm contractor on site to repair control panel.	Working	Backwall of Offices hot. Temperatures on control needs to be addressed. Intermex makes loud noise.	Rooms 120, 121, 122, 123, 125; Males and storage closets all being treated for remediation. Upstairs rest room 213 water damage from ceiling to wall.	No	No	Busted fire sprinkler water line in cafeteria. Extensive damage to the cafeteria.	Yes, as long as cafeteria is not being accessed.	Sageport ES - Busted fire sprinkler water line in Cafeteria, only Cafeteria has water damage. FD shut off fire sprinkler main; school still has water. 2:18 - Remediation contractor capped water line, on site cleaning out water. 2:18 - Fire alarm contractor on site working on the fire alarm control panel; board is fixed. Fire alarm contractor made repairs to sprinkler system and system was rechecked. Fire alarm contractor made repairs to fire alarm system, still 2 minor issues but system is functional. Remediation contractor still has drying equipment installed. 2:20 @ 9pm - All areas are dry. No demolition necessary except for what was removed to contain the leak.
Shelburne Bus Barn	All looked good upon initial arrive. Once we walked inside, it was noted that water was flowing gushing out from vehicle bay. Alarm was immediately notified.	Yes	Working	Working	All Good	In second building only - water gushing from vehicle bay.	N/A	N/A	N/A	Yes	
Shoemaker HS	None	Yes	Makes Noise	Yes Classroom/portable phones were not all working	Toilet Flushing issues	Small gym water leak from ceiling kids room leak. Between 1106 and 1107 small drying puddle. Room 1402 and 1404 sinks running and cannot be turned off.	Yes	Yes	Yes	Yes	Shoemaker HS 2:18 - No water on campus or in fieldhouse. Maintenance following up with City. 2:18 - Pool of water in hallway by 1106/1107. Leak above ceiling in storage room between 1106/1107. 2:19 - Plumbing contractor should be able to get to campus today. 9pm - contractor unable to make it to campus today. 2:20 @ 10:45am - Small gym water leak from ceiling. Kids room leak.
Skipecha ES	None	Yes	Working	Working	No Water	Major water damage to east wing 1st and 2nd floors due to busted water fountain water line; remediation necessary. Cafeteria Facilities	No	Yes	No	I would not recommend employees outside of campus administration remaining at this time.	2:19 @ 11:00am - Entire west wing (1st & 2nd floors) is flooded. Water main is off. Plumbing contractor is on site. 2:19 @ 1:30pm - KESD was notified of a fire alarm. Plumbers were on campus at the time, possibly cut off sprinklers when water line was turned on. 9pm - Fire alarm disconnected while repairs are underway. 2:19 @ 9pm - Water fountain water line busted in wall. Flooded 4 second floor rooms and about 8 first floor rooms; possibly need major demolition and reconstruction. Remediation contractor is still on site extracting water. 2:20 - Remediation contractor will be removing 2.5' of walls on second floor and 4' on first floor classrooms @ 3:30pm. All water has been extracted. Demolition has begun; Construction Dumpster is onsite. Air movers and dehumidifiers installed throughout building.

Smith MS	None	Yes	Working	Working	No toilets flushed. Staff bathroom across from Room 200 has been used although it doesn't flush.	600 hallway leak repaired prior to walk thru. Room 610E door open, no visible water. Rooms 611, 612, 614, 615 & 616 fans and air dries running but no visible water on the floor, walls or in the water collection area (trash cans or sinks).	No	Yes	Yes	Yes	Snack MS - 600 hallway leak - reported 2/14 2:15 @ 6pm - Maintenance shut off water at select locations 2:15 - Remediation contractor removed standing water from floors and installed fans Main water came up through the floor drain overnight KHD plumber scheduled to work on repairs on 2/18; remediation contractor to follow 2:19 @ 6pm - Acid tank was frozen, contractor cleared the line May need remediation or custodians can possibly clean the water 2:20 @ 6pm - All areas extracted twice; KHD crew mopped up 1st water event Dehumidifiers and fans installed and running Building will be checked tonight to determine if still wet; if dry, equipment will be removed
Sugar Loaf ES	None	Yes	Fire panel alarm is beeping and says: Testable	Working	Toilets not flushing in boy's restrooms across from room 8. Cafeteria boys restrooms toilets do not flush. Girls across from rm 13 & 14 toilets do not flush. Boys (some half) toilets, do not flush.	Leaking toilet and low water pressure 100 hallway girls restroom. **Ceiling drip in room 19 computer lab. Water dripping onto ceiling tile. The water has not entered the classroom, but if it continues to drip, it might.	Yes	Yes	Yes	Yes	
Technology Services Center	None	Yes	Working	Working	All Good	Small drip from cable conduit in Cultural side electrical room. 10x10 inch wet spot on the floor.	Yes	Yes	Yes	Yes	
Timber Ridge ES	None	Yes	Working	Working	All Good	All Good	Yes	Yes	Yes	Yes	
Transportation	None	Yes	Working	Working	All Good	Training room number two has a small leak on the air vent.	N/A	N/A	N/A	Yes	
Timmer ES	None	Yes	Working	Working	All Good	Room 200 - standing water and 2 sinks full of water (Pahs and storage carts in this room) Custodian closed the leak to sink - intecoon kept popping while we were here. Water damage at the entrance.	Yes, hot heavy odor	Yes	Yes	Not at this time standing water in room with no electricity	Timmer ES 2:18 - No water on campus Maintenance following up with City 2/19 @ 6pm - Plumber investigated, no issues found. Note: Water has been turned back on 2:20 @ 6pm - Standing water in room 200, sink overflowing. Maintenance notified and on their way Cranked line on boiler, no hot water to see sink Leak repaired
Union Grove MS	None	Yes	Working	Working	All Good	All Good	Yes	Yes	Yes	Yes	Union Grove MS Fire alarm went off at some point and ED shut off water.
Visible Village ES	None	Yes	Working	Working	All Good	All Good	Yes	Yes	Yes	Yes	
West Ward ES	None	Yes	Working	Working	No Water	All Good	No	Yes	Yes	Yes	West Ward ES 2:17 - City notified us of visible water leaks from outside of building and shut off water meter 2:18 - Plumbing contractor visited campus and found water coming up from ground on City's side of water meter. Notifying City for repair. 2:20 @ 6pm - City working on water meter. 3pm - We were notified by City that repair man will be repaired tomorrow?
Willow Springs ES	None	Yes	no beeping or noises but panel states there is system trouble and system bypass	Working	No Water	All Good	No	Yes	Yes	Yes	Willow Springs ES 2:18 - No water on campus Maintenance following up with City